

F-3. ROAD CONSTRUCTION GENERAL SPECIFICATIONS AND INSPECTION REQUIREMENTS

General Specifications

1. All work shall comply with the provisions of Section VI-G. Streets and Roads of the Sanders County Subdivision Regulations
 2. All work shall meet the provisions of the latest edition of the Montana Public Works Standard Specifications (MPWSS)
 3. Clear and grub to width necessary to construct typical road sections (See F-1 and F-2)
 4. Subgrade:
 - a. Free of all topsoil, vegetation, roots, stumps, organic matter, frozen material, refuse, construction debris or other man-made items within top 12" of subgrade
 - b. Shape and compact subgrade surface
 - c. Proof roll subgrade prior to placement of base
 5. Base:
 - a. Minimum of 12" of 3" minus "Pit Run" Gravel
 - b. Shape for minimum 2% cross slope and compact base
 6. Surface Course – Gravel
 - a. Minimum of 3" of 1 ½" minus Base Gravel as surface course
 - b. Uniform thickness across width of surface
 - c. Shape for minimum 2% cross-slope for surface drainage and compact
 7. Surface Course – Asphalt
 - a. Minimum of 3" of 1 ½" minus Base Gravel placed over base
 - b. Minimum of 2" of Hot Mix Asphalt Pavement as surface course
 - c. Uniform thickness across width of surface
 - d. Shape for minimum 2% cross-slope for surface drainage and compact
-

Inspection Requirements

All construction shall be inspected by the County District Road Foreman at the following stages.

- A. Pre-Construction
- B. Clearing and Grubbing: Subgrade shall be proof rolled in presence of Road Foreman prior to placement of base material
- C. Base material
- A. Final Acceptance: After completion of surface course